



Fire Inspector I Certification

Skill # 8

Maximum Time Allowed: **30 min.**

INSTRUCTIONS TO THE CANDIDATE

The candidate, as an individual and given fire flow test results and water supply data, shall verify that fire flows for a site are in accordance with the applicable codes and standards and all deficiencies are identified, documented, and reported in accordance with the policies of the jurisdiction having authority.

CANDIDATE PERFORMANCE	1 st Attempt		2 nd Attempt	
	Yes	No	Yes	No
◆ Candidate has informed the evaluator that they have been trained in this skill	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
VERIFY FIRE FLOW	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Opened the hydrant fully	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Opened petcock on the pitot tube to drain water from chamber	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Closed petcock	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Placed blade opening of pitot tube in corner of stream and at a distance approximately half the diameter of the orifice	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Places pitot tube parallel to opening	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Records pressure from gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Properly locates the pressure for each orifice on the chart	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Total steps candidate must complete to pass:	6	Total		<input type="checkbox"/>

◆ **Critical Step** - Failure on this step results in failure of the entire skill.

Candidate Name _____

1st Evaluator Signature _____ Date _____

2nd Evaluator Signature _____ Date _____



Fire Inspector I Certification

Skill # 8

Objective(s): 4.3.16, 4.3.16(B) NFPA Standard 1031 2003 Edition

INSTRUCTIONS TO THE PROCTOR/EVALUATOR

EQUIPMENT LIST: Skill 8 Scenario Packet, Pitot Tube, Clipboard, and Pens/Pencils,

Proctor/Candidate Comments

I was informed of the task steps missed that resulted in the failure of this skill and the OSU-FST re-test policies.

Candidate Signature

Date

Test Re-test Date: _____ Location: _____