



## Fire Fighter I Certification

<b>Skill # 1 Inspecting PPE and SCBA</b>	<b>Maximum Time Allowed: 10 min.</b>
--	--------------------------------------

### INSTRUCTIONS TO THE CANDIDATE

Identifies and inspects all PPE and SCBA components so that they are determined to be ready for service or reported otherwise. Candidate will provide all NFPA compliant PPE and SCBA which includes: helmet, hood, coat, pants, suspenders, boots, gloves, hearing protection, eye protection, SCBA, Facepiece and PASS device.

<b>CANDIDATE PERFORMANCE</b>	1 <sup>st</sup> Attempt		2 <sup>nd</sup> Attempt	
	Yes	No	Yes	No
<b>INSPECTION PPE</b>				
Candidate has informed the evaluator that they have been trained in this skill ♦				
Identifies all PPE is present (helmet, hood, coat and pants, suspenders, boots, gloves and PASS device.)				
Inspect all articles of PPE for damage and cleanliness.				
NFPA compliant tags found in all articles.				
Verbalizes the need and use of hearing protection.				
Verbalizes the need and use of eye protection.				
Verbalizes cleaning and reporting of damage found during inspection of PPE.				
<b>INSPECTION SCBA</b>				
Check harness assembly for cleanliness and damage.				
Check condition of cylinder for cleanliness and damage.				
Check cylinder no less than 90% full. ♦				
Cylinder opened fully verifies no leaks.				
Low pressure alarm function verified.				
Checks gauges and/or indicators (i.e. heads up display) are functioning within manufacturer's guidelines.				
Demonstrates PASS alarm and describes all functions and modes.				
Inspects facepiece for cleanliness and damage.				
Dons facepiece and checks for proper seal. Note: Not all face pieces are designed for a seal check without regulator being attached and activated.				
Regulator function checked by taking normal breath(s). ♦				
By-pass and/or purge valve checked, if applicable. ♦				
Removes facepiece and bleeds down SCBA.				
Prepares SCBA for immediate reuse or reports otherwise.				
<b>Total steps candidate must complete to pass:</b>	<b>16</b>	<b>Total</b>		

♦ **Critical Step** - Failure on this step results in failure of the entire skill.

Candidate Name \_\_\_\_\_

1<sup>st</sup> Evaluator Signature \_\_\_\_\_ Date \_\_\_\_\_

2<sup>nd</sup> Evaluator Signature \_\_\_\_\_ Date \_\_\_\_\_



## Fire Fighter I Certification

### Skill # 1 Inspecting PPE and SCBA

Objective(s): 5.1.2, 5.3.1 NFPA 1001 Standard 2008 Edition

#### INSTRUCTIONS TO THE PROCTOR/EVALUATOR

Performs a routine inspection of PPE and SCBA so that they are determined to be ready for immediate use or reported otherwise.

Proctor/Candidate Comments

I was informed of the task steps missed that resulted in the failure of this skill and the OSU-FST re-test policies.

\_\_\_\_\_  
Candidate Signature

\_\_\_\_\_  
Date