



Live Fire Evaluation

Skill # 5 Dumpster and Stack Fire	Maximum Time Allowed: 30 min.											
<u>INSTRUCTIONS TO THE CANDIDATE</u>												
The candidate, while operating as a member of a team and under direct supervision, will extinguish fires involving Class A materials that are located outside and in a Dumpster												
CANDIDATE PERFORMANCE			<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="2" style="text-align: center;">1st Attempt</td> <td colspan="2" style="text-align: center;">2nd Attempt</td> </tr> <tr> <td style="text-align: center;">Yes</td> <td style="text-align: center;">No</td> <td style="text-align: center;">Yes</td> <td style="text-align: center;">No</td> </tr> </table>		1 st Attempt		2 nd Attempt		Yes	No	Yes	No
1 st Attempt		2 nd Attempt										
Yes	No	Yes	No									
◆ Candidate has informed the evaluator that they have been trained in this skill												
PREPARATION												
Verbalizes hazards that may be present with these types of fires												
Wears full PPE and SCBA "on air".												
Knock down fire from a distance; caution must be used not to spread burning debris.												
STACKED MATERIAL												
Verbalizes that if material is stacked and poses a collapse hazard they will position themselves outside the collapse zone.												
Use an appropriate nozzle pattern to penetrate the stacked material thoroughly												
Shuts down nozzle so that water hammer is avoided												
Separate and overhaul piles of burning material												
Fire extinguished												
TRASH CONTAINER												
Tool used to open trash container lids – not hands												
Head not placed over edge of trash containers												
Does not stir up trash to overhaul												
Fire extinguished												
Total steps candidate must complete to pass:		12	Total									

Candidate Name _____

1st Evaluator Signature _____ Date _____

2nd Evaluator Signature _____ Date _____



Live Fire Evaluation

Skill #5 Dumpster and Exterior Stack Fire

Objective(s): **5.3.8 NFPA Standard 1001 2008 Edition**

INSTRUCTIONS TO THE PROCTOR/EVALUATOR

- Live Fire Skill #5 Candidate Exam Sheet or Booklet
- 1.5" or greater attack line and back-up line
- OSU-FST accredited Fire Fighter I Training/Burning Facility
- Stacked prop that includes Class A material the can be stacked and burned. (A propane fire simulator may be substituted for this prop)
- Dumpster prop that can be filled with Class A material and ignited. (A propane fire simulator may be use in this prop)
- NFPA 1403, 1500 and 1584 Compliance Plan
- Hand tools (pike poles, etc.)

Proctor/Candidate Comments

I was informed of the task steps missed that resulted in the failure of this skill and the OSU-FST re-test policies.

Candidate Signature

Date