



Fire Fighter II Live Fire Evaluation

Skill # 2 Control Flammable Gas Cylinder Fire	Maximum Time Allowed: 15 min.
--	--------------------------------------

INSTRUCTIONS TO THE CANDIDATE

The candidate, given various equipment, will control a flammable gas cylinder fire operating as a member of a team, given an assignment, a cylinder outside a structure, and appropriate equipment, so that crew integrity is maintained, contents are identified, safe havens are identified prior to advancing, open valves are closed, flames are not extinguished unless the leaking gas is eliminated, the cylinder is cooled, cylinder integrity is evaluated, hazardous conditions are recognized and acted upon, and the cylinder is faced during approach and retreat.

CANDIDATE PERFORMANCE	1 st Attempt		2 nd Attempt	
	Yes	No	Yes	No
◆ Candidate has informed the evaluator that they have been trained in this skill	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CONTROL FLAMMABLE GAS CYLINDER FIRE				
◆ PPE/SCBA properly donned and remains intact until outside of hazardous area	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Exposures/Cylinder is cooled during preparation for approach	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Cylinder integrity is evaluated, hazardous conditions are recognized and acted upon	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Team leader briefs team and identifies/announces the safe haven prior to approach	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cylinder type/contents identified (evaluator prompt)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Appropriate attack/back-up/exposure lines in place	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Team protection maintained with fog stream at all times – including retreat	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Hazard faced until retreat to safe haven is reached	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Team integrity maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Exposures/pressure vessels are continually cooled during approach and retreat	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Contain the fire prior to attempting other control measures	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Select appropriate tools/procedures and attempt to shut-off valve(s)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fire not intentionally extinguished	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
◆ Unburned vapors from leaking cylinder/s are properly managed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Assignment completed: situation controlled	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Total steps candidate must complete to pass:	12	Total		

◆ **Critical Step** - Failure on this step results in failure of the entire skill.

Candidate Name _____

1st Evaluator Signature _____ Date _____

2nd Evaluator Signature _____ Date _____



Fire Fighter II Live Fire Evaluation

Skill # 2 Control Flammable Gas Cylinder Fire

Objective(s): 6.3.3, 6.3.3.B NFPA Standard 1001 2008 Edition

INSTRUCTIONS TO THE PROCTOR/EVALUATOR

EQUIPMENT LIST: OSU-FST LPG Trailer or approved cylinder prop/s

NOTE: Live Fire Testing must be conducted in accordance with NFPA 1403, 1500 and 1584.

RETEST POLICY: This skill is eligible for on-site retest in accordance with OSU FST policies and procedures.

Proctor/Candidate Comments

I was informed of the task steps missed that resulted in the failure of this skill and the OSU-FST re-test policies.

Candidate Signature

Date